



*bringing water to life*

# NOTICE

## MOTOR BREAKDOWN AT CRAIGHEAD WATER TREATMENT WORKS

AW has experienced a breakdown at Craighead pumpstation that supplies Peddie Treatment Works with raw water. There are three motors and two motors are affected and are not working. Presently the pumpstation is operating with one motor and that resulted to less raw water for the plant. The water treatment works has to at 50% of its capacity due to insufficient raw water and as a result there are many areas without water.

One motor is with the service provider and will be installed back on Monday after repairs. Once installed the pumpstation will be restored to capacity. The second motor cannot be removed at the moment due to inclement weather.

Amatola Water apologizes for the inconvenience caused by this breakdown and is prioritizing the repairs to resolve this breakdown.

**For more information contact the Manager: Stakeholder and Communications on 043 707 3734  
Toll Free number 080 086 4699 (Amatola Water Call Centre) [www.amatolawater.co.za](http://www.amatolawater.co.za)**

**#SAVEWATER**

**Fraud hotline: 0800 203 287**